

CABLE SECRETARIAT PERSON/UNIT NOTIFIED

ADVANCE COPY ☐ ISSUED ☐ SLOTTED

BY: \_\_\_\_\_ AT: \_\_\_\_\_ Z

DISSEM BY: \_\_\_\_\_ PER \_\_\_\_\_ # \_\_\_\_\_

ACTION ☐ RID COPY

**SECRET**  
(When Filled In)

REPRODUCTION OF THIS COPY PROHIBITED

INDEX: ☐ YES ☐ NO

CLASSIFY TO FILE NO. \_\_\_\_\_

X-REF TO FILE NO. \_\_\_\_\_

FILE RID ☐ RET. TO \_\_\_\_\_ BRANCH ☐ DESTROY ☐ SIG. \_\_\_\_\_

INFO: \_\_\_\_\_

FILE VR. Com mo 7, P. 1, DDS 2, Sec 4, PPB, (Cops 4)

1	6
2	7
3	8
4	9
5	10

5X1A

25X1A S E C R E T 250236Z FEB 69 CITE [REDACTED] 1063

25 FEB 69 IN 00249

5X1A

25X1A

1. ON-SITE INSPECTION BY [REDACTED] DISCLOSED THAT THE PRESENT MODIFICATIONS DO NOT PROVIDE ADEQUATE FIRE PROTECTION OF ELECTRONIC EQUIPMENT IN OPERATIONS AREAS. IT IS RECOMMENDED THAT A "CHANGE ORDER BE APPROVED FOR THE INSTALLATION OF A SMOKE DETECTOR SYSTEM IN THE MAX I AREA AND IN ALL RETURN AIR DUCTS.

2. THIS JOB IS APPROXIMATELY 60 PERCENT COMPLETED AND SHOULD BE FINISHED BY JULY THEREFORE IT IS REQUESTED THAT WE BE ADVISED AS SOON AS POSSIBLE WHETHER WE CAN AMEND THIS CONTRACT.

S E C R E T

Copy to Joe

REC'D

C

DC

EX

SAC

SA

C/RE

RO

+ C/RE

2

APPROVAL

COMMENT

CONCURRENCE

INFORMATION

PREPARE REPLY

RETURN

FILE

25X1A

**SECRET**